



COST EFFECTIVE DANISH DH CASES CONTRIBUTION TO SUBTASK B RAMBOLL ENERGY ANDERS DYRELUND

CONTENT

Infrastructure networks


- Tårnby District Heating, from gas boilers to district heating (DH)
- Høje Taastrup DH, from chillers to district cooling (DC) network with storage
- Høje Taastrup DH, from centralized to decentralized supply of DH end-users for DH and DC
- Danish Building and Property Agency, from campus network to city DH
- Greater Copenhagen DH, Integration of local DH systems and available production in a city

CONTENT (2)


Production cases

- Nymindesgade military campus: from oil to local CHP based on biogas
- Gram DH, Solar heat, electric boiler, heat pump, gas CHP,
- Technical University of Denmark, Campus, electric boiler, gas CC CHP, heat pump
- Silkeborg DH, Solar heat, gas CC CHP, heat pump
- Waste incineration, ARC Copenhagen
- Biomass CHP, HOFOR Copenhagen
- Tårnby DH, Heat pump to combined DH and DC and surplus heat from waste water

MODEL AND METHODOLOGY FOR PLANNING DISTRICT ENERGY



TÅRNBY DH, FROM GAS BOILERS TO DH PART OF THE GREATER COPENHAGEN DISTRICT HEATING SYSTEM



TÅRNBY DISTRICT HEATING

Owned by Tårnby Municipality


Established in 1985, replace oil

Heat from the heat transmission company, CTR, Tårnby

Municipality is co-owner of CTR

Zoning of the networks:


- Green districts: DH system established in 1985
- Blue districts: Planning to shift from gas to DH around 2020
- District with-out colour: One-family houses: an option to shift from gas boilers to DH or to heat pumps in 2030-2050



DATA FOR TÅRNBY DH

- 132 consumers, incl. Copenhagen Airport campus
- 178 GWh annual heat production
 - 168 GWh annual heat sale, of which 55 to the airport
 - 9,5 GWh annual heat loss, equal to 5,3%
 - **8,5 GWh annual heat loss for new pipes, calculated**
 - 12,7 GWh losses incl. Airport network, equal to 7%
 - **11,7 GWh inkl. the network of the airport campus**
- 28 km DH network, DN20-DN500 + 10 km airport
- Normal supply temperature 75-95 dgr.C
- Normal return temperature 50 dgr.C
- Preinsulated pipes from 1985, surveillance system
- Remaining life-time of the network? 50 years more ?
- Heat exchanger between DH and campus is removed

RAMBOLL



- Maximal demand **60 MW**
- Heat capacity to the network
 - Heat exchanger transmission: 60 MW
 - Local back-up oil boiler 60 MW
 - Planned heat pump DH&DC 6 MW

PLAN FOR EXTENSION OF THE DH SYSTEM

- Strategic development of the DH system
- The key figure "investment in network" divided by "heat sale" is a good indicator
- Due to low density heat load and longer network per heat sale
- Therefore, heat losses is also a good indicator

Development of Tårnby DH	Demand	Network invest.	Key figure	Heat loss	Alternative
Districts	MWh	1000 DKK	1000DKK/MWh	%	individual
First network in 1985	115.909	253.079	2,2	6,8%	gas boiler
Campus in long-term development	54.953	74.175	1,3	5,6%	oil boiler
Total incl. Campus	170.862	327.254	1,9	6,3%	
First extension 2020	30.838	42.594	1,4	5,0%	gas boiler
New urban development	5.635	17.826	3,2	10,4%	heat pump
Second extension 2025?	11.201	41.147	3,7	11,0%	gas boiler
Total without small houses	218.535	428.821	2,0	6,6%	


HØJE TAASTRUP DH, FROM CHILLERS TO DISTRICT COOLING (DC) NETWORK WITH STORAGE



IEA ANNEX 73, DANISH CASES FOR COST EFFECTIVE DH AND DC
170418

PROJECT PROPOSAL APPROVED

- Screening model to identify the potential
- Total long-term project approved
 - Interconnected DC grid
 - Heat pump for combined DH and DC, with no curtailment of heat
 - Chilled water storage
 - ATES system
 - Share of heat storage pit
- First stages in operation in 2018:
 - Heat pump in 3 steps to Copenhagen Markets whole sale vegetables etc.
 - Energy plant prepared for extension to maximal capacity



HØJE TAASTRUP DH, FROM CENTRALIZED TO DECENTRALIZED SUPPLY OF DH END-USERS FOR DH AND DC



THE DH AND DC DIRECTLY TO THE END-USER

- DH to each apartment in the building
- DC to each tenant in Copenhagen Markets for vegetables and flowers
- If the building or campus owner wants to avoid internal heating and cooling systems, DH and DC are can be delivered directly to individual end-users. The only condition is
 - Stop valves and a heat meter
 - Agreement between building owner and utility on ownership of pipes in the buildings, and level of insulation



DANISH BUILDING AND PROPERTY AGENCY, FROM CAMPUS STEAM TO CITY DH

We buy, rent, build, develop, maintain and energy optimise buildings



THE CAMPUS OWNER


One of Denmark's largest public property enterprises and developers

- We administer approximately 4 million m² properties
- 3 million m² state-owned properties used as offices and by universities – with a value exceeding DKK 37 billions (EUR 4.9 billions)
- 1.3 million m² private leases
- Operating revenue; DKK 3 billions per year (EUR 0.4 billions)
- Construction expenses; DKK 3 billions per year (EUR 0.4 billions).
- Approximately 230 employees





THE QUEENS PALADS

- 1951 from a centralized boiler to DH steam
- 2009 from 4-pipe system and steam to DH directly to 9 local substations
- Active energy management via the DH system




ROSKILDE UNIVERSITY

- 1970: oil boiler plant and local network to 33 building substations
- 1988: from oil boiler to DH
- 2012 City DH network replaces the campus network and 33 new substations are established
- From 2,4 km to 2,0 km pipes
- Smaller dimensions
- Heat loss savings 1.500 MWh (25%)
- More efficient energy management from campus owner via the DH system



GREATER COPENHAGEN DH, INTEGRATION LOCAL DH SYSTEMS AND AVAILABLE PRODUCTION IN A CITY






INTEGRATING 3 HEAT TRANSMISSION DH AND 20 DISTRIBUTION DH AND CAMPUSSES WITH PRODUCTION

Greater Copenhagen DH&C, in year	2018	2038
Supplied population	1 million	
Supplied heated floor area million m ²	70	80 ?
Heat production in average, GWh	10.800	10.800
Waste to energy CHP	30%	30%
Biomass CHP	62%	50%
Heat pumps, electric boilers	0%	17%
Biomass boilers, or CHP by-pass	2%	2%
Peak boilers, gas, oil,	6%	1%
District cooling combined with heat, GWh	0	330
Heat storage volume 1000 m ³	75	2,000
Cool storage volume in 1000 m ³	4	110

SIMULATION OF HEAT AND ELECTRICITY WITH ENERGYPRO


Simulation of the heat production on hourly basis for a typical year

- Heat load profile for the system
- Electricity price profile, NORDPool market





DEVELOPMENT OF PRODUCTION CAPACITY

- Existing CHP from gas and coal to biomass
- New 400 MW heat wood chip fuelled CHP will start in 2020
- Our prognosis for 2018-2038:
- 400 MW heat pumps
- 800 MW electric boilers
- 2 million m³ thermal storage





RESILIENT POWER GENERATION WITHOUT THERMAL LOSSES DEMAND RESPONSE, NO RES IS CURTAILED

- 2018
 - 365 days
 - 300 hours



- 2038
 - 365 days
 - 300 hours




NYMINDEGAB MILITARY CAMPUS: FROM OIL TO LOCAL CHP BASED ON BIOGAS



FROM OIL TO BIO GAS CHP AT THE NYMINDEGAB CAMPUS

- Nymindegab is a military installation in Jutland covering approximately 2.96 km².
- There are **24** buildings in the installation and it houses Home Guard training facilities
- Originally, the buildings were connected to a campus pre-insulated pipe DH system, supplied with an oil boiler.
- Recently a biogas fueled gas engine has been installed to supply the base load
- The biogas is produced at a near-by biogas plant processing bio waste from the farming






GRAM DH, SOLAR HEAT, ELECTRIC BOILER, HEAT PUMP, GAS CHP,



IEA ANNEX 73, DANISH CASES FOR COST EFFECTIVE DH AND DC
170418

STRONG DEMAND RESPONSE – ACTS AS A VIRTUAL BATTERY

- Heat production 30 GWh
- 120,000 m³ heat storage pit
- 44,000 m² solar panels (61%)
- A 10 MW electric boiler (15%)
- A 900 kW heat pump (8%)
- Industrial surplus heat (8%) and
- A 5 MWe/6 MWth CHP gas engine (8%)
- Gas boilers for spare capacity (0%)
- ENREGYPro for planning
- MENTOR PLANNER for daily operation



TECHNICAL UNIVERSITY OF DENMARK, CAMPUS, ELECTRIC BOILER, GAS CC CHP, HEAT PUMP

DTU CAMPUS, LONG-TERM PLAN ELEC- TRICITY, DH AND DC TO ALL BUILDINGS

- 2017
- Gas fuelled CC plant 30 MW elec./30 MW heat
 - Total efficiency of the plant 90%
 - Heat storage tank 8.000 m³
- 2020
- Gas fuelled CC plant 30 MW elec./30 MW heat
 - Interconnected to the City DH part of Greater Copenhagen
 - Electric boiler at CHP plant 40 MW
 - Heat pump to DC system 3,4 MW cold / 4,4 MW heat
- Towards 2050
- Building floor area increases significantly
 - Heat demand increases slightly and lower return temperature
 - Cooling demand increases significantly
 - New heat pump capacity to combined heating and cooling
 - Chilled water storages
 - Ground source cooling



IEA ANNEX 73, DANISH CASES FOR COST EFFECTIVE DH AND DC
170418

SILKEBORG DH, SOLAR HEAT, GAS CC CHP, HEAT PUMP



MUNICIPAL OWNED DH SYSTEM IN SILKEBORG

ANNUAL HEAT TO THE NETWORK: 400 GWH


Before	• Gas fuelled CC plant	108 MW elec./85 MW heat
	• Total efficiency of the plant	87%
	• Heat storage tank	2*16.000 m ³
	• Heat production from CHP	80 GWh
	• Heat production boilers	320 GWh
From 2017	• Gas fuelled CC plant	106 MW elec./120 MW heat
	• Total efficiency of the plant	102%
	• Heat storage tanks	4 x 16.000 m ³ = 64.000 m ³
	• Large-scale solar heating	156.000 m ² (world largest in 2018)
	• Absorption heat pumps	25 MW cooling capacity
	• Heat production solar	70 GWh
	• Heat pump from solar	10 GWh
	• Heat production CHP	210 GWh
	• Heat pump condensation	30 GWh
	• Heat production boilers	80 GWh



WASTE INCINERATION, ARC COPENHAGEN



ARC COPENHILL – NO WASTE TO BE DUMPED AT LANDFILLS ENERGY PRODUCTION - FLEXIBILITY - AND LIVEABILITY




Credit: BIG

BIOMASS CHP, HOFOR COPENHAGEN



HOFOR, MUNICIPAL OWNED MULTI UTILITY, OWNER OF DH, DC, CHP, GAS, WATER AND WASTE WATER

- Amagerværket Bio4 CHP plant under construction
- Fluidized bed boiler
 - Heat pump flue gas condensation
 - Low quality wood chip
 - 500 MW fuel capacity
 - 110% total efficiency
- Maximal power:
 - 150 MW electricity
 - 400 MW heat
- Minimal power:
 - 0 MW electricity
 - 550 MW heat





TÅRNBY DH, HEAT PUMP TO COMBINED DH AND DC AND SURPLUS HEAT FROM WASTE WATER



COST EFFECTIVE DISTRICT HEATING AND COOLING

Symbiosis between DH and DC

- No installations for production in buildings
- Heat pump serves two purposes:
 - Generate cooling capacity in summer
 - Produces efficient heat in winter



IEA ANNEX 73, DANISH CASES FOR COST EFFECTIVE DH AND DC 170418

THANK YOU FOR YOUR ATTENTION

QUESTIONS ?

WWW.RAMBOLL.COM

AD@RAMBOLL.COM

+45 51 61 87 66